

HOLMES & NARVER, INC.
Engineers - Constructors

DECLASSIFIED PER DOE
LETTER DATED JULY, 15, 1994
FROM ANTON SINISGALLI TO
DIANE S. NIXON

TO: General Superintendant

JOB: 942

FROM: Resident Engineer

RE: Weather Station Generators

DATE: 23 September 1957

405992

Your memo of 21 June 1957 has been well considered and every effort to complete designs based upon using 60KW, 3 phase generators whenever available has been made. We have purchased a limited number of these 60 KW, 3 phase generators because we were under obligation to use the DOD furnished 15 KW generators we have on hand, wherever possible.

I have delayed answering your memo until final design could be firmed up. It now appears that at most of the stations we will use one 60 KW generator and the day use of only one 15 KW generator with another 60 KW as standby for both.

EHW:jlm

cc: J/S Chrono
J/S Central
J/S Engineering
✓ J/S Engineering Reading File

REPOSITORY NATIONAL ARCHIVES
PACIFIC SOUTHWEST REGION
COLLECTION RG 326 ATOMIC ENERGY COMMISSION
BOX No. 52670 (#28) A16164 326-658730
FOLDER WEATHER AND RADSAFE STATIONS